

NSF Test Data Waco, Texas

Date	Influent E-Coli	Effluent E-Coli Ave <14 Max <240	
10/21/13	980000	1.1	less than
10/23/13	687000	1.0	less than
10/25/13	1610000	1.1	less than
10/28/13	5840000	1.1	less than
10/30/13	1720000	1.0	less than
11/1/13	816000	1.0	less than
11/4/13	435000	1.0	less than
11/6/13	816000	1.0	less than
11/8/13	921000	1.0	less than
11/11/13	816000	1.1	less than
11/13/13	770000	1.0	less than
11/15/13	579000	1.0	less than
11/18/13	1990000	3.1	
11/20/13	1050000	1.0	
11/22/13	1550000	1.0	
11/25/13	770000	1.1	less than
11/26/13	411000	1.0	less than
11/27/13	613000	1.0	less than
12/2/13	461000	1.0	less than
12/4/13	1300000	1.0	less than
12/6/13			
12/9/13			
12/11/13	411000	1.0	less than
12/13/13	517000	1.0	less than
12/16/13	687000	1.1	less than
12/18/13	387000	1.0	less than
12/20/13	548000	1.0	
12/23/13	579000	1.0	less than
12/25/13			
12/27/13	517000	1.0	less than
12/30/13	387000	1.0	less than
1/1/14	260000	1.0	less than
1/3/14	1200000	1.0	less than
1/6/14	127000	1.0	less than
1/8/14	387000	1.0	less than
1/10/14	156000	1.0	less than
1/13/14	345000	1.0	
1/15/14	210000	2.0	
1/17/14	102000	1.0	less than
1/20/14	62700	1.0	less than
1/22/14	158000	1.0	less than
1/24/14	81600	1.0	less than
1/27/14	161000	1.0	less than
1/29/14	326000	1.0	less than
1/31/14	866000	1.0	less than
2/3/14	4880000	1.0	less than
2/5/14	461000	4.1	
2/7/14			
2/10/14	397000	1.0	less than
2/12/14	461000	1.0	less than
2/14/14	411000	1.0	less than

Median	517000	1
Min	62700	1
Max	5840000	4.1
Avg	834474	1
Std Dev	1066222	1